

December 15, 2021

Marian Chicago 396 Wegner Dr. West Chicago, IL 60185

Attn: Mr. Pat Hurrle

Re: Cleanroom Certification

Dear Mr. Hurrle:

On December 7, 2021, we had the opportunity to perform testing in the above captioned facility in order to evaluate the capacity of engineering controls to support process requirements. Certification results are summarized below:

LOCATION	ISO CLASSIFICATION	TEST REPORT NO.	DATE CERTIFIED	NEXT DUE
Clean Room	ISO Class 7	211207-1,2,3,100,101,201	December 2021	June 2022
Material Pass Room	ISO Class 7	211207-4,5,6,100,101,201	December 2021	June 2022
Gowning Room	ISO Class 7	211207-7,8,9,100,101,201	December 2021	June 2022

I will be available to discuss these results in depth. Please do not hesitate to call with any questions you may have.

Respectfully Submitted,

Edward Paligreeni, Operations Manager LabMetrics, Inc.

EP/bf file