



Clean Room Performance Certification

This is to certify that the clean room named below, and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Marian, Inc.
 2787 S. Freeman Rd.
 Monticello, IN. 47960

Clean Room:	Controlled Environment - 141
Design Type:	Vertical Flow
Test Report Number:	26-022701
Standard Used:	ISO 14644-1:2015
Date Tested:	February 27, 2026
Recertification Due:	February 2027
Particle Count Cleanliness Class	ISO Class 7 for 0.5 µm particle size At Rest
Air Changes per hour test:	N/A
Pressurization Test:	Pass

Kent Lewis, President

March 3, 2026

Date

Any questions regarding this certification should be directed to:

Circle City Cleanroom
 P.O. Box 14, Beech Grove, IN 46107
 317-223-6873



Clean Room Performance Certification

This is to certify that the clean room named below, and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Marian, Inc.
 2787 S. Freeman Rd.
 Monticello, IN. 47960

Clean Room:	Controlled Environment - 143
Design Type:	Vertical Flow
Test Report Number:	26-022702
Standard Used:	ISO 14644-1:2015
Date Tested:	February 27, 2026
Recertification Due:	February 2027
Particle Count Cleanliness Class	ISO Class 7 for 0.5 µm particle size At Rest
Air Changes per hour test:	N/A
Pressurization Test:	PASS

Kent Lewis, President

March 3, 2026

Date

Any questions regarding this certification should be directed to:

Circle City Cleanroom
 P.O. Box 14, Beech Grove, IN 46107
 317-223-6873



Clean Room Performance Certification

This is to certify that the clean room named below, and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Marian, Inc.
2787 S. Freeman Rd.
Monticello, IN. 47960

Clean Room:	Controlled Environment - 144
Design Type:	Vertical Flow
Test Report Number:	26-022703
Standard Used:	ISO 14644-1:2015
Date Tested:	February 27, 2026
Recertification Due:	February 2027
Particle Count Cleanliness Class	ISO Class 8 for 0.5 μm particle size At Rest
Air Changes per hour test:	N/A
Pressurization Test:	PASS

Kent Lewis, President

March 3, 2026

Date

Any questions regarding this certification should be directed to:

Circle City Cleanroom
P.O. Box 14, Beech Grove, IN 46107
317-223-6873



Clean Room Performance Certification

This is to certify that the clean room named below, and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Marian, Inc.
 2787 S. Freeman Rd.
 Monticello, IN. 47960

Clean Room:	Clean Room 3
Design Type:	Vertical Flow
Test Report Number:	26-022704
Standard Used:	ISO 14644-1:2015
Date Tested:	February 27, 2026
Recertification Due:	February 2027
Particle Count Cleanliness Class	ISO Class 7 for 0.5 µm particle size At Rest
Air Changes per hour test:	N/A
Pressurization Test:	PASS

Kent Lewis, President

March 3, 2026

Date

Any questions regarding this certification should be directed to:

Circle City Cleanroom
 P.O. Box 14, Beech Grove, IN 46107
 317-223-6873



Clean Room Performance Certification

This is to certify that the clean room named below, and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Marian, Inc.
 2787 S. Freeman Rd.
 Monticello, IN. 47960

Clean Room:	Ante Room
Design Type:	Vertical Flow
Test Report Number:	26-022704
Standard Used:	ISO 14644-1:2015
Date Tested:	February 27, 2026
Recertification Due:	February 2027
Particle Count Cleanliness Class	ISO Class 7 for 0.5 µm particle size At Rest
Air Changes per hour test:	N/A
Pressurization Test:	PASS

Kent Lewis, President

Mar 3, 2026

Date

Any questions regarding this certification should be directed to:

Circle City Cleanroom
 P.O. Box 14, Beech Grove, IN 46107
 317-223-6873